

EFFICIENCY REQUIREMENTS

Equipment type	Size category	Sub-category	Minimum efficiency requirement(s)	Customer incentive
Heat Pumps, Air-Cooled (Cooling Mode)	< 65,000 Btu/hr (three phase)	Split system	14.0 SEER & 12.0 EER	\$50/ ton
		Single package	14.0 SEER & 11.6 EER	\$50/ ton
	≥ 65,000 Btu/hr and < 135,000 Btu/hr	Split system and Single package	11.1 EER & 12.1 IEER	\$50/ ton
	≥ 135,000 Btu/hr and < 240,000 Btu/hr	Split system and Single package	10.7 EER & 11.7 IEER	\$50/ ton
	≥ 240,000 Btu/hr	Split system and Single package	10.1 EER & 10.7 IEER	\$50/ ton
Heat Pumps, Air-Cooled (Heating Mode)	< 65,000 Btu/hr (three phase)	Split system	8.5 HSPF	\$50/ ton
		Single package	8.0 HSPF	\$50/ ton
	≥ 65,000 Btu/hr and < 135,000 Btu/hr	47°F db/43°F wb outdoor air	3.4 COP	\$50/ ton
		17°F db/15°F wb outdoor air	2.4 COP	\$50/ ton
	≥ 135,000 Btu/hr	47°F db/43°F wb outdoor air	3.2 COP	\$50/ ton
		17°F db/15°F wb outdoor air	2.1 COP	\$50/ ton
Heat Pumps, Water-Source	< 135,000 Btu/hr	86°F Entering Water (Cooling Mode)	14.0 EER	\$50/ ton
		68°F Entering Water (Heating Mode)	4.6 COP	\$50/ ton
Heat Pumps, Ground-source or Groundwater-source	All sizes	—	ENERGY STAR Qualified	\$50 / ton
Unitary Commercial Air Conditioners, Air-Cooled	< 65,000 Btu/hr (single phase)	Split system	CEE Tier 2 16.0 SEER & 13 EER	\$50 / ton
Heat Pumps, Air-Cooled (Cooling Mode)	< 65,000 Btu/hr (single phase)	Split system	15.0 SEER & 12.5 EER	\$50 / ton
		Single package	15.0 SEER & 12.0 EER	
Heat Pumps, Air-Cooled (Heating Mode)	< 65,000 Btu/hr (single phase)	Split system	9.0 HSPF	\$50 / ton
		Single package	8.5 HSPF	